



Securities and Exchange Commission of Pakistan
63-NIC Building, Blue Area, Islamabad
(Administration Department)

February 6, 2013

Subject: Procurement of UPS 3KVA

The Commission intends to purchase a **UPS 3 KVA** while specifications are given as under:

S. No.	Items & Specification		Qty
1	UPS 3KVA (SMART)		1
	Make	APC or Equivalent	
	Model	SURTD-3000XLI or equivalent	
	Output Power Capacity	2100 Watts/3000 VA	
	Output Voltage Distortion	Less than 3%	
	Input/output power chords	Included for all I/O Connections	
	Nominal input/output voltage	230V	
	Output connections	(8) IEC 320 C13	
		(2) IEC 320 C19	
		(2) IEC Jumpers	
	Efficiency at Full Load	92%	
	Waveform Type	Pure Sine Wave	
	Battery Modules	Included	
	Battery Type	Maintenance-free sealed Lead-Acid battery with suspended electrolyte; leak-proof	
	Typical Recharge Time	2.50 Hrs	

- **Price** must be inclusive of all taxes applicable by Govt. of Pakistan.
- **Delivery** at CRO Office Faisalabad within with in one week of receiving of Purchase Order.
- **Validity** Minimum 30 Days from quoted date.
- **Bid Submission** Time within 7 days after receiving this RFQ.
- **Warranty Period:** Warranty will be covered in Faisalabad Office or anyother SECP office. 1 year warranty for consumable parts (batteries) and 2 year repair/replace warranty for non consumable parts is required.

If you are interested, please submit sealed quotation for the above item to the undersigned SECP, 63-NIC Building, Jinnah Avenue, Blue Area, Islamabad within the specified period.

Waiting for your quick response.

M. Ubaidullah Khalid
AD (Admin)