



Securities and Exchange Commission of Pakistan
63-NIC Building, Blue Area, Islamabad
(Administration Department)

March 21, 2013

Subject: Request for Quotation for 3KVA UPS Systems

The Commission intends to purchase **3KVA UPS Systems** with following specifications:

S. No.	Items & Specification		Qty
1	UPS 3KVA Online		02
	Make	APC or Equivalent	
	Model	SURTD-3000XLI or Equivalent	
	Output Power Capacity	2100 Watts/3000 VA	
	Output Voltage Distortion	Less than 3%	
	Input/output power chords	Included for all I/O Connections	
	Nominal input/output voltage	230V	
	Output connections	(8) IEC 320 C13	
		(2) IEC 320 C19	
		(2) IEC Jumpers	
	Efficiency at Full Load	92%	
	Waveform Type	Pure Sine Wave	
	Battery Modules	Included	
	Battery Type	Maintenance-free sealed Lead-Acid battery with suspended electrolyte; leak-proof	
	Typical Recharge Time	2.50 Hours	

Note: Product of equivalent Make, Brand and Model may be quoted.

- **Price** must be inclusive of all taxes applicable by Govt. of Pakistan.
- **Delivery** within four weeks of receiving of Purchase Order.
- **Validity** minimum 30 days from quoted date.
- **Bid Submission** time within 7 days after receiving this RFQ.
- **Warranty Period:** 1 year warranty for consumable parts (batteries) and 2 year repair/replace warranty for non-consumable parts is required.
- **Installation and after sales support** to be covered in Head Office (ISB) or any other SECP office in major cities of Pakistan.
- **Quotes MUST be submitted in the above specified tabular format.**

If you are interested, please submit sealed quotation for the above item to the undersigned SECP, 63-NIC Building, Jinnah Avenue, Blue Area, Islamabad, within the specified period.

With best regards,

Assistant Director (Admin)
Administration Department