



Securities and Exchange Commission of Pakistan  
63-NIC Building, Blue Area, Islamabad  
(Support Services Division)  
(Administration Department)  
\*\*\*\*\*

**Subject: Purchase of Dehumidifier**

The Commission intends to invite quotations for Purchase of Dehumidifier for its Head Office as per specifications given at **Annex-A**

**Terms and Conditions**

- **Price** must be inclusive of all taxes applicable by Govt. of Pakistan.
- **Quantity:** (01) may increase.
- **Validity:** Minimum 30 Days from quoted date.
- **Bid Submission:** as per date given on SECP website.
- **Warranty:** 1 year comprehensive warranty.

***Note: SECP reserves the right to cancel purchase at any stage and delete any item.***

**If you are interested, please submit sealed quotation for the above item to the undersigned SECP, 63-NIC Building, Jinnah Avenue, Blue Area, and Islamabad within the specified period.**

With best regards.

M. Ubaidullah Khalid  
Assistant Director (Admin)

### Technical Specifications for Dehumidifier for HO Data Center

S. No.	Specification	Requirements
1.	Coverage Area	720 square feet
2.	Water Removal Capacity	50 Liters (~100 pints) minimum
3.	Operating Temperature Range	5 C° to 55 C°
4.	Humidity Range	45% - 95 %
5.	Air Circulation (CMH)	200
6.	Bucket Capacity	50 Liters minimum
7.	Drain Hose	Required
8.	Power Supply	230 V / 50 Hz
9.	Water-Filled Alarm	Required
10.	Warranty	01 year comprehensive

**Note:**

1. Room material: Gypsum walls, aluminum sheet, glass door
2. 4x 4 ton air conditioners installed in the data center (2x ceiling units, 2x tower units)