



Securities and Exchange Commission of Pakistan
63-NIC Building, Blue Area, Islamabad
(Support Services Division)
(Administration Department)

Subject: Purchase of Dehumidifier

The Commission intends to invite quotations for Purchase of Dehumidifier for its Head Office as per specifications given at **Annex-A**

Terms and Conditions

- **Price** must be inclusive of all taxes applicable by Govt. of Pakistan.
- **Quantity:** (01) may increase.
- **Validity:** Minimum 30 Days from quoted date.
- **Bid Submission:** as per date given on SECP website.
- **Warranty:** 1 year comprehensive warranty.

Note: SECP reserves the right to cancel purchase at any stage and delete any item.

If you are interested, please submit sealed quotation for the above item to the undersigned SECP, 63-NIC Building, Jinnah Avenue, Blue Area, and Islamabad within the specified period.

With best regards.

M. Ubaidullah Khalid
Assistant Director (Admin)

Technical Specifications for Dehumidifier for HO Data Center

S. No.	Specification	Requirements
1.	Coverage Area	720 square feet
2.	Water Removal Capacity	50 Liters (~100 pints) minimum
3.	Operating Temperature Range	5 C° to 55 C°
4.	Humidity Range	45% - 95 %
5.	Air Circulation (CMH)	200
6.	Bucket Capacity	50 Liters minimum
7.	Drain Hose	Required
8.	Power Supply	230 V / 50 Hz
9.	Water-Filled Alarm	Required
10.	Warranty	01 year comprehensive

Note:

1. Room material: Gypsum walls, aluminum sheet, glass door
2. 4x 4 ton air conditioners installed in the data center (2x ceiling units, 2x tower units)