



Securities and Exchange Commission of Pakistan
63-NIC Building, Blue Area, Islamabad
(Support Services Division)
(Administration Department)

Subject: Purchase of Actuators for Fire Suppression System.

The Commission intends to invite quotation for purchase of Actuators for Fire Suppression System as per specifications given **Annex-A**

Terms and Conditions

- **Price** must be inclusive of all taxes applicable by Govt. of Pakistan.
- **Quantity:** Five (05) may increase or decrease.
- **Delivery:** time within one weeks of receiving of P.O.
- **Validity:** Minimum 30 Days from quoted date.
- **Warranty Period:** 05 Years
- **Bid Submission:** as per date given on SECP website.

Note: SECP reserves the right to cancel purchase at any stage and delete any item.

If you are interested, please submit sealed quotation for the above item to the undersigned SECP, 63-NIC Building, Jinnah Avenue, Blue Area, and Islamabad within the specified period.

With best regards.

M. Ubaidullah Khalid
Assistant Director (Admin)

Technical Specifications for Fire Suppression System (FSS) Actuators

S.No	Specification	Requirement
1	Body	Mild Steel & Dull Nickel
2	Swivel nut	Brass CZ121
3	Actuation Pin	Stainless Steel
4	Actuation Type	Manual Force Required
5	Rest Requirement	1" BSPP
6	Connection	24 Vdc
7	Power Requirement	0.2A
8	Current	5 kgf (11 . lb.f)
9	Manual Actuation Force	3-pin plug connector
10	Diode Type	Suppression
11	Life Span	10 years From manufacture
12	Temperature Range	(-)20 centigrade to 55 centigrade
13	Testing	100% Check on start /Finish Position
14	Safety Approvals	Under writers Laboratories Recognized to UL508 Tested In accordance with UL864

Technical Evaluation Criteria

MUST be compatible with fire suppression system & Cylinders installed at SECP HO