



Securities and Exchange Commission of Pakistan

63-NIC Building, Blue Area, Islamabad

(Administration Department)

Subject: Quotations Required for Supply, Installation and Commissioning of Prime Power 6 KVA on load or 6.8 KVA Patrol, Gas or Diesel Generator at CRO Quetta.

The Commission intends supply, installation and commissioning of 6.8 KVA or prime power 6 KVA on load gas, petrol or diesel Generator at CRO Quetta. **Terms of Reference are attached as Annex "A"**

Terms & Conditions

- **Price** must be inclusive of all taxes applicable by Govt. of Pakistan.
- **Delivery, Installation and commissioning** time within two weeks of receiving of Purchase Order.
- **Validity** Minimum 30 Days from quoted date.
- **Bid Submission Time** as given on SECP Website.

Note: Interested firm may contact following SECP official in order to visit site and quote accordingly

Abdul Rehman Khan Tareen

In charge CRO Quetta

Tel: +92-81-2844136

Mob: 0333-7831955

Email: abdul.rahman@secp.gov.pk

If you are interested, please submit sealed quotation for the above required services to at above mentioned address or the undersigned at

SECP, 63-NIC Building, Jinnah Avenue, Blue Area, Islamabad.

With best regards.

M. Ubaidullah Khalid
Assistant Director (Admin)

Term of Reference’s

The Securities & Exchange Commission of Pakistan, Islamabad invites quotations for supply, installation and commissioning of prime power 6 KVA on load or 6.8 KVA power capacity stand-by Diesel, petrol/gas Generator of reputable brand like Honda or equivalent including power cable, Sound proof canopy and auto transfer switch **at Company Registration Office Quetta**. Please separately quote the cost of sound proof canopy.

Other specifications should be included but not limited to the following,

- Maximum output power: prime power 6 kW or 6.8 KVA
- Heavy duty wheels and handle for easy mobility
- Built-in maintenance-free battery 18 Amp
- Electric start system with low noise
- 0-50 liter fuel tank
- 4-stroke single-cylinder engine
- Suitable for all weather conditions
- Style: Portable Generators

Operation manual will be provided along with complete specifications, after sale maintenance requirements, change time of lubricant and other oil service etc.

Warranty: Minimum one year from the date of commissioning of standby Diesel Generator set against all manufacturing defects, faulty material and/or incorrect performance detected during the normal course of operation.

Suppliers are to include warranty/guarantee for at least one year.

After Sale Maintenance Services agreement: Maintenance services would be required on quarterly basis. Firm’s expert technician will visit in every quarter for the equipment maintained.

Maintenance would include:

- Routine visit to carry out normal maintenance and checking of electrical circuitry, panels, breakers etc.
- Replacement of consumable spares (if required) such as oil filter, fuel filter, water filter, air filter etc. as specified by Manufacturer’s manual and as required. The cost of all consumable spares and material would be to the account of the Client “SECP”.

Evaluation Criteria: Evaluation Criteria will be based on technical and financial evaluation,

Technical Marks:	40
▪ Clientage Profile:	15
▪ Quoting well reputed Brands:	5
▪ Warranty Terms:	10
▪ After Sale maintenance services:	10

Financial Marks:	60
Total Marks:	<u>100</u>