



Securities and Exchange Commission of Pakistan
63-NIC Building, Blue Area, Islamabad
(Administration Department)

Subject: Supply and Installation of Power Points/Sockets and Power DBs at CRO Lahore

The Commission intends to purchase and install power points/sockets in CRO Lahore as per specifications given below:

S. No	Item	Brand	Quantity
1.	Wire	(7/29) Pakistan Cable/equivalent	As per actual
2.	Power Sockets	Multi Schneider/Clipsal or equivalent	180 or as per actual (decided by SECP)
3.	UPS Power socket	Multi Schneider/Clipsal or equivalent (Different Color to identify UPS socket)	90 or as per actual (decided by SECP)
4.	Back Boxes	Smart one box iron solution with single plate for three power sockets (2 power, 1 UPS)	90 or as per actual (decided by SECP)
5.	Circuit Breaker	Hager/Schneider or equivalent	06x 32 Amp or as per actual w.r.t. Power DBs 60x 16 Amp or as per actual 10x 20Amp or as per actual
6.	Power DBs	Siemens or equivalent (Iron Base)	06 or As per actual
7.	Duct/Chanel Fittings	Adamjee/Dura or equivalent	As per actual

Terms and Conditions

- **Prices** MUST be inclusive of all taxes applicable by Govt. of Pakistan.
- **Delivery & Installation time** within one week of receiving of P.O.
- **Validity** Minimum 30 days from the quoted date.
- **Bid/Quotation Submission Time** as per SECP website.

NOTE:

1. Dismantling of existing power infrastructure is part of the revamping job.
2. LESCO and UPS power points must be clearly identifiable.
3. Complete tagging and DBs power diagram should be pasted on every DB with all details.
4. Back box with plate should be branded and of good quality.

If you are interested, you may visit site and submit sealed quotation for the above item to the undersigned SECP, 63-NIC Building, Jinnah Avenue, Blue Area, and Islamabad within the specified period.

With best regards,

M. Ubaidullah Khalid
Assistant Director (Admin)