



Securities and Exchange Commission of Pakistan
4th floor, State Life Building No.2,
Wallace Road Off I.I. Chundrigar Road
(Support Services Division)
(Administration Department)

Subject: Quotation Required for Supplying of UPS 5VA with installation.

The Commission intends to purchase subject, as per specifications given below (Annex-A):

- **Interested Vendors / Firms** must be registered with sales tax department and having national tax number (NTN).
- **Price** must be inclusive of all taxes applicable by Govt. of Pakistan.
- **Rates** of each item must be quoted separately.
- **Bid Submission.** As per SECP website.
- **Delivery** should be provided within 3 days of Purchase Order issuance.
- **Validity Minimum** 15 Days from quoted date.
- **Quantity mentioned** above might decrease/increase.
- **Warranty Period:** MUST be mentioned in quotation.

If you are interested, **MUST** visit and then kindly submit sealed quotation for the above items to the undersigned, SECP, 4th floor, State Life Building No.2, Wallace Road Off I.I. Chundrigar Road, Karachi within the specified period.

An early and quick response will be highly appreciated.

With best regards,

Deputy Director (Admin)

Annex-A

Specification Sheet for 5KVA UPS System

S. No.	Specification	Quantity
1.	APC or equivalent	01
	Output Power Capacity	4.5kWatts / 5.0kVA
	Max Configurable Power (Watts)	4.5kWatts / 5.0kVA
	Output Voltage Distortion	Less than 2%
	Topology	Double Conversion Online
	Nominal Input Voltage	230V
	Input Frequency	40-70 Hz (Auto Sensing)
	Output Frequency (sync to mains)	50/60Hz +/- 3 Hz
	Other Output Voltages	220, 240V
	Input Connections	Hard Wire 3 wire (1PH+N+G)
	Input Voltage Range	160V – 275V
	Other Input Voltages	220 , 240V
	Output connections	(2) IEC Jumpers (Battery Backup) (6) IEC 320 C13 (Battery Backup) (4) IEC 320 C19 (Battery Backup)
	Bypass	Internal Bypass (Automatic and Manual)
	Waveform Type	Sine Wave
	Crest Factor	3:1
	Typical Recharge Time	Not more than 02 hours
	Battery Modules	Included
	Nominal Battery Voltage	192V
	Battery Type	Maintenance-free sealed Lead-Acid battery with suspended electrolyte: leak-proof
	Interface Port(s)	RJ-45 10/100 Base-T, RJ-45 Serial, Smart-Slot, USB
	Control Panel	Multi-function LCD status and control console
Warranty	1 Year warranty for consumable parts (batteries) and 2 Years repair/ replace warranty for non-consumable parts	
Delivery	SECP Karachi Office	